



STATE OF FLORIDA
DEPARTMENT OF HEALTH AND REHABILITATIVE SERVICES

DATE: August 19, 1992
 TO: [REDACTED] Building Inspector Supervisor
 FROM: ^{SV} Samuel Velez, Environmental Supervisor I
 SUBJECT: Mr. [REDACTED] property at 16383 Seminole Blvd., Brooksville

Received
 FEB 26 1993
 Dove

On Wednesday, August 12, 1992, at the request from Mrs. Abele, personnel from this office conducted a sanitary inspection on the above-referenced property. The following are our findings and the corrective actions necessary to comply with state and county regulations:

A. The septic tank system servicing the house.

1. The tank collapsed.
2. The tank is too small.
3. The bottom of tank is not acceptable (not solid concrete).
4. Only 94 square feet of drainfield and appears to be clogged.
5. Dry well used for disposal of washing machine waste water.

COMPLIANCE: Apply and obtain an onsite sewage disposal permit; install a system as per Chapter 10D-6, F.A.C.

B. Private potable water system servicing the house and mobile home.

1. Garbage around and over the system.

COMPLIANCE: Remove garbage from area. Sample water to verify it is bacteriologically safe. Time of compliance: 1 week.

C. Garbage and trash scattered everywhere; some areas with pile of burned garbage, other areas with holes and buried garbage. A

COMPLIANCE: Remove garbage and trash and dispose of properly at county sanitary landfill. Time of compliance: 2 weeks.

NOTE: This department will coordinate with Code Enforcement the enforcement of violations. Please do not restore power rights to house until notified by this office that owner is in compliance.

SV/lg

cc: Mr. Mel Abele
 Frank McDowell, Code Enforcement
 HERNANDO COUNTY PUBLIC HEALTH UNIT
 602 SOUTH BROAD STREET • BROOKSVILLE, FLORIDA 34601
 Telephone (904) 754-4067 • Environmental Health (904) 754-4072

LAWTON CHILES, GOVERNOR

EXHIBIT

tabbles

8

76 ABELE #1

07/01/97

HERNANDO COUNTY SERVICE REQUEST SYSTEM
INVESTIGATIVE REPORT
BUILDING DIVISION
JUNE 06, 1992

FILE: 021892 DATE: 06/06/92 TO: BLD CODE: 90
FROM: RMM CEO#: 210 DIST#: 1 STATUS: ~~NEW~~ DUE DATE: 10/31/94

REQNAME: ROSARIO SHEILA REQPHONE#: 904/ -
REQADDRESS: 1525 BLANFORD STREET BROOKSVILLE FLORIDA

VNAME: MEL ABELE VIOPHONE# 813/ -
VIOADDRESS: 8023 WINTER STREET

LOCATE: 16383 SEMINOLE BOULEVARD ISTACHATTA ACRES
REFERRED TO: DETAILS:
RE-INSPECTIONS: 0

06/02/92 RECEIVED A WRITTEN COMPLAINT REQUESTING THAT SUBJECT PROPERTY BE
INSPECTED FOR POSSIBLE CONDEMNATION RMM
07/17/92 PER JFF, LTR SENT TO WREC BY GHR, BLDG OFF, REQ POWER SHUT OFF. WRE
COMPLIED. POWER NOT TO BE RESTORED UNTIL BLDG BROUGHT TO COMPLIANCE. CSJ
3-26-93 LTR TO ATTY JOHNSTON FOR O & E CSJ
07-15-93 2ND LTR FOR O & e REPORT JH
09-13-93 MEMO TO B SCARFF FOR STATUS JH
2-23-95 FILE CLOSED IN 95 CLOSED COMPL CABINET JH

907 ABELE #1